

State Water Resources Control Board

March 14, 2019

(Via email and Certified Mail)

Mr. Gary Walker
Owner / Operator
Cardin Flight Service
1950 Airport Road
Red Bluff, California 96080
cardanaircraft@yahoo.com

CERTIFIED MAIL
NO. 7018 0680 0000 1017 6182

Mr. Scott Miller
Assistant Public Works Director
City of Red Bluff
555 Washington Street
Red Bluff, California 96080
smiller@cityofredbluff.org

CERTIFIED MAIL
NO. 7018 0680 0000 1017 5604

**SUBJECT: NOTICE OF VIOLATION; UNDERGROUND STORAGE TANK SYSTEMS
LOCATED AT CITY OF RED BLUFF AIRPORT, 1760 AIRPORT BOULEVARD,
RED BLUFF**

Dear Mr. Walker and Mr. Miller:

As part of an initiative by the State Water Resources Control Board (State Water Board) to ensure compliance at government-owned and/or operated underground storage tank (UST) facilities in California, the State Water Board staff inspected the USTs at your facility on March 8, 2019, pursuant to authority under Health and Safety Code (H&SC), chapter 6.7, section 25289.

The State Water Board has identified the following violations pursuant to H&SC, chapter 6.7, and California Code of Regulations (CCR), title 23, chapter 16:

No.	Violation	Tank	Start Date	Stop Date	Regulation
1	Failure to Monitor Product Piping – The sensor in the turbine sump was incorrectly positioned at an angle. The test boot on the supply line was preventing a leak from being detected at the earliest opportunity. This violation was corrected at the time of inspection.	Tank #1	March 8, 2019	March 8, 2019	23 CCR 2630(d)
2	Failure to Maintain Site Map/Plot Plan – The site map in CERS does not show the piping layout for the UST systems.	All	March 8, 2019	Ongoing	23 CCR 2711(a)(8)

Office of Enforcement | 801 K Street, Suite 2300 | Sacramento, CA 95814 | 916.341.5272

E. JOAQUIN ESQUIVEL, CHAIR | EILEEN SOBECK, EXECUTIVE DIRECTOR

You are directed to correct the ongoing violations and submit compliance documentation to the State Water Board and Tehama County Environmental Health within sixty (60) days from the date of this letter. Have your Designated Operator make specific notations in the next monthly designated operator report indicating the ongoing violations have been corrected. The monthly designated operator report and any associated photos must be submitted as proof of compliance.

Please send all compliance documentation to the following:

State Water Board

Mr. Joseph Lovesee
UST Enforcement Unit
Office of Enforcement
State Water Resources Control Board
801 K Street, Suite 2300
Sacramento, California 95814
joseph.lovesee@waterboards.ca.gov


Local CUPA

Ms. Lauri Dilworth
Registered Environmental Health Specialist III
Tehama County Environmental Health
663 Washington Street
Red Bluff, California 96080
ldilworth@co.tehama.ca.us

Pursuant to Health and Safety Code, chapter 6.7, section 25299, the owner and operator of the tank(s) are liable for a penalty of \$500 to \$5,000 per tank, per day of violation. These penalties will continue to accrue until the violations have been corrected.

If you have any questions, please contact me at (916) 323-0600, or by email at brian.taylor@waterboards.ca.gov.

Sincerely,



Brian Taylor
Sr. Water Resource Control Engineer (Supv.)
UST Enforcement Unit
Office of Enforcement

cc: *(via email only)*

Ms. Lauri Dilworth, REHS III
Tehama County Environmental Health
ldilworth@co.tehama.ca.us